Robert Singletary
Executive Director

OKLAHOMA Environmental Quality

Kevin Stitt
Governor

RECEIVED
11/5/2026 aaj
Copy - Gene & Robert

November 3, 2026

Gene McCullough, Public Works Director
Clinton Public Works Authority
P.O. Box 1177
Clinton, Oklahoma 73601

Re: Permit No. SL000055260438
Sewer System Improvements
Facility No. S-10804

Dear McCullough:

Enclosed is Permit No. SL000055260438 for the construction of One (1) new 1,420 gpm lift station with emergency overflow basin and generator, 228 linear feet of twenty-four (24) inch PVC sanitary sewer line, 9842 linear feet of twelve (12) inch HDPE sanitary sewer line, 140 linear feet of ten (10) inch PVC sanitary sewer line, and all appurtenances to serve the Sewer System Improvements, Custer County, Oklahoma.

The project authorized by this permit should be constructed in accordance with the plans approved by the Department of Environmental Quality ("DEQ") on November 3, 2026. Any deviations from the approved plans and specifications affecting capacity, flow, or operation of units must be approved, in writing, by DEQ before changes are made.

Receipt of this permit should be noted in the minutes of the next regular meeting of the Clinton Public Works Authority, after which it should be made a matter of permanent record.

Approved plans and specifications are available upon request.

Respectfully,

Toby Harden, P.E.
Construction Permit Section
Water Quality Division

Enclosure